



प.स.:- २०८२/०८३

च.नं.

# लेकम गाउँपालिका

गाउँ कार्यपालिकाको कार्यालय  
रातामाटा, दार्चुला  
सुदूरपश्चिम प्रदेश, नेपाल



E-mail:- lekam.rmun@gmail.com

info@lekammun.gov.np

Web: lekammun.gov.np

## क्याटलग सपिङ्ग विधिबाट जेनेरेटर खरिद सम्बन्धी सूचना !

सूचना प्रकाशन मिति: २०८२/०६/१०

लेकम गाउँपालिकालाई आवश्यक पर्ने 30 KVA जेनेरेटर उपलब्ध गराउन इच्छुक इजाजत पत्र प्राप्त उत्पादक कम्पनी वा अधिकृत/आधिकारिक विक्रेताहरूले आवश्यक कागजातहरू संलग्न राखी उपलब्ध गराउने जेनेरेटरको आधिकारीक स्पेसिफिकेशन, गुणस्तर, मूल्य र सुविधा सहितको विवरण (क्याटलग वा ब्रोसर) संलग्न राखी रीतपूर्वक (शिलबन्दी गरी स्पष्ट रूपमा अंक र अक्षरमा रकम खुलाई) सूचना प्रकाशन भएको मितिले १५ (पन्ध्र) दिन भित्र यस कार्यालयमा प्रस्ताव पेश गर्नु हुन यो सूचना प्रकाशन गरिएको छ।

### तपसिल:

क्र.स.	विवरण	जम्मा रकम (मु.अ.क. सहित)	प्रस्ताव पेश गर्ने अन्तिम मिति	कैफियत
१	30 KVA जेनेरेटर	१०,००,०००/-	२०८२/०६/२४ कार्यालय समयभित्र	

### आवश्यक कागजातहरू:

१. प्रस्ताव पेश गर्ने इजाजत पत्र प्राप्त उत्पादक कम्पनी वा अधिकृत/आधिकारिक विक्रेताहरूले अनिवार्य रूपमा प्रस्ताव पेश गर्ने व्यहोराको लिखित निवेदन,
२. रु १००० को सक्कलै राजस्व भौचर (लेकम गाउँपालिकाको लक्ष्मी सनराईज बैंकमा रहेको आन्तरिक राजस्व खाता नम्बर ०९००३००२०० मा जम्मा गरेको) वा कार्यालयबाट जारी गरेको रसिद,
३. जेनेरेटर आपूर्ती उत्पादक कम्पनी वा अधिकृत/आधिकारिक विक्रेताको दर्ता प्रमाणपत्रको प्रतिलिपि,
४. स्थायी लेखा नम्बर (PAN) दर्ता प्रमाण पत्रको प्रतिलिपि,
५. गत आ.व.२०८१/०८२ को कर चुक्ता प्रमाण पत्रको प्रतिलिपि,
६. उक्त कार्यका लागि विस्तृत स्पेसिफिकेशन यस कार्यालयको वेबसाइट [www.lekammun.gov.np](http://www.lekammun.gov.np) बाट डाउनलोड गर्न सकिने छ।

  
२०८२/०६/१०

(शेखर चन्द्र ओझा)

नि.प्रमुख प्रशासकीय अधिकृत

नि. प्रमुख प्रशासकीय अधिकृत



प.स.:- २०८२/०८३

च.नं.



# लेकम गाउँपालिका

गाउँ कार्यपालिकाको कार्यालय

रातामाटा, दार्चुला

सुदूरपश्चिम प्रदेश, नेपाल



E-mail:- lekam.rmum@gmail.com

info@lekammun.gov.np

Web: lekammun.gov.np

## Technical Specifications GENERATOR 30 KVA

S.N	Criteria	Requirements	Offered Specifications	Remarks
1	General	30 kVA, Compact, Aesthetically Silent Diesel Generator set Suitable for ambient temperature between -10 to 50 degree centigrade. The manufacturing year shall not be earlier than 2025.	Manufacturer: Brand: Type/Model: Country of Origin: Mfg. Year:	
2	Engine	Engine rated power not less than 38 HP, 3 cylinders, liquid cooled diesel engine	Make: Model:	
3	Alternator	Brushless with class H insulation, 50Hz frequency, Voltage Regulation+/-1%, 0.8 PF Lag		
4	Voltage	230V (1 phase) / 415 V 3-phase		
5	Noise Level	Not more than 75dBA @1 meter distance		
6	Fuel Consumption (Ltrs/Hr)@100% load	Not more than 7.8 (Lower preferred)		
7	Fuel Tank Capacity	Not less than 60 litres		
8	Battery Capacity	90AH or higher		
9	System DC Voltage (Starting)	12 V		
10	Aspiration	TC/TA		
11	Lubrication Oil Sump Capacity	Not more than 7 litres		
12	Lube Oil Change Period	Not less than 500 hrs or 6 months		
13	Coolant Capacity	Not more than 13 litres		
14	Emission Standard	CPCB II		
15	Governer	Mechanical / Electronic type		
16	Control Panel	Microprocessor based Automatic Mains Failure (AMF) control Unit		

*(Signature)*

“व्यावसायिक र सिर्जनशील प्रशासन: विकास, समृद्धि र सुशासन”

प्रशासकीय अधिकृत



# लेकम गाउँपालिका



प.स.:- २०८२/०८३

च.नं.



गाउँ कार्यपालिकाको कार्यालय

रातामाटा, दार्चुला

सुदूरपश्चिम प्रदेश, नेपाल

E-mail:- lekam.rmun@gmail.com

info@lekammun.gov.np

Web: lekammun.gov.np

		Special Alarm conditions including Low Lub Oil Pressure (LLOP), high water temperature (HWT), Overload, Under/over speed, low fuel level, etc.		
		ATS Panel with controller & battery charger with MCCB. Control shall consists of a multi- function meter which displays AC Current/Voltage, Frequency, Power Factor, Kilowatt Hour, PF, etc.		
17	Earthing	Minimum Two earthing seperately for neutral and body. Earth electrodes and earthing conductors along with couplings, clamps, etc. as per standard.		
18	Instructions	All signs and instructions in the equipment shall be in English		
19	Manuals	One copy of the operator's and Owner's Instructions and maintenance manual in English shall be supplied with equipment		
20	Authorization Letter	Supplier shall include Authorization Letter from manufacturing company.		
21	Training	Supplier shall provide training on operation, general maintanance and servicing after delivery and installation.		
22	Warranty	Manufacturer shall provide a minimum of one year warranty after acceptance (higher preferred)		
23	Related Service	Supplier shall guarantee on-time availability of spare parts, servicing and maintenance facility for at least 5 years after the warranty period.		
24	Delivery	One unit 30 kVA Diesel Generator set shall be delivered and installed at: <b>Lekam Rural Municipality, Office of Executive</b>		

**Note:**

The major items are indicated by bold and highlighted letters/alphabets/ figures in the technical specifications.

Non-compliance of these major items will result in non-responsive of the offer.

*(Signature)*  
न. प्रमुख प्रशासकीय अधिकृत